



# 7/8" Corrugated on 16 ga Purlins

## Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.5:12				Roof Slope: 1.5:12 to 6:12			Roof Slope: 6:12 to 12:12		
	Thickness	Field	Edge	Corner	Field	Edge	Corner	Field	Edge	Corner
120D	24 ga	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00
		-24.2 psf	-41.1 psf	-62.3 psf	-22.1 psf	-39 psf	-58 psf	-24.2 psf	-28.4 psf	-28.4 psf
130D	24 ga	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00
		-28.5 psf	-48.4 psf	-73.2 psf	-26 psf	-45.9 psf	-68.3 psf	-28.5 psf	-33.5 psf	-33.5 psf
140D	24 ga	5.00	5.00	4.50	5.00	5.00	5.00	5.00	5.00	5.00
		-33.2 psf	-56.2 psf	-85.1 psf	-30.3 psf	-53.4 psf	-79.3 psf	-33.2 psf	-39 psf	-39 psf
150D	24 ga	5.00	5.00	4.00	5.00	5.00	4.25	5.00	5.00	5.00
		-38.2 psf	-64.7 psf	-97.8 psf	-34.9 psf	-61.4 psf	-91.1 psf	-38.2 psf	-44.8 psf	-44.8 psf
160D	24 ga	5.00	5.00	3.50	5.00	5.00	3.75	5.00	5.00	5.00
		-43.6 psf	-73.7 psf	-111.3 psf	-39.8 psf	-69.9 psf	-103.8 psf	-43.6 psf	-51.1 psf	-51.1 psf
170D	24 ga	5.00	4.75	3.00	5.00	5.00	3.25	5.00	5.00	5.00
		-49.3 psf	-83.3 psf	-125.8 psf	-45.1 psf	-79.1 psf	-117.3 psf	-49.3 psf	-57.8 psf	-57.8 psf
180D	24 ga	5.00	4.25	2.50	5.00	4.25	2.75	5.00	5.00	5.00
		-55.4 psf	-93.5 psf	-141.1 psf	-50.6 psf	-88.7 psf	-131.6 psf	-55.4 psf	-64.9 psf	-64.9 psf
190D	24 ga	N.G.	N.G.	N.G.	5.00	4.00	2.25	5.00	5.00	5.00
		-61.8 psf	-104.3 psf	-157.3 psf	-56.5 psf	-99 psf	-146.7 psf	-61.8 psf	-72.4 psf	-72.4 psf

**Notes:**

1. Allowable spacing is based on a Design Pressures listed in the FBC 2017 Approval, FL10999.1 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and patterns are shown in the Approval.

2. Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, " Roof Slopes, and Roof Zones shown, assuming 10 square feet of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 25 feet.

3. Allowable spacing is determined for wind suction using the combination  $0.6DL + 0.6W$ . Also considered is the appropriate inward wind pressure, 20 psf live load and the weight of the panel.

N.G. indicates the panel is not recommended for this application.

- ① - FIELD
- ② - EDGE
- ③ - CORNER
- A - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF ROOF MEAN HEIGHT BUT NOT LESS THAN 3'-0"

