



# Image II on 19/32" Plywood

## Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.5:12				Roof Slope: 1.5:12 to 6:12			Roof Slope: 6:12 to 12:12		
	Thickness	Field	Edge	Corner	Field	Edge	Corner	Field	Edge	Corner
120C	0.032"	2.00	1.00	0.50	2.00	1.00	0.50	2.00	1.50	1.50
130C	0.032"	1.50	1.00	0.50	2.00	1.00	0.50	1.50	1.50	1.50
140C	0.032"	1.50	0.50	0.50	1.50	0.50	0.50	1.50	1.00	1.00
150C	0.032"	1.00	0.50	0.50	1.50	0.50	0.50	1.00	1.00	1.00
160C	0.032"	1.00	0.50	0.50	1.00	0.50	0.50	1.00	1.00	1.00
170C	0.032"	1.00	0.50	0.50*	1.00	0.50	0.50	1.00	0.50	0.50
180C	0.032"	0.50	0.50	0.50*	1.00	0.50	0.50*	0.50	0.50	0.50
190C	0.032"	0.50	0.50	0.50*	0.50	0.50	0.50*	0.50	0.50	0.50

**Notes:**

- Allowable spacing is based on a Design Pressures listed in the FBC 2017 Approval, FL11560.3 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, \* Roof Slopes, and Roof Zones shown, assuming 10 square feet of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 25 feet.
- Allowable spacing is determined for wind suction using the combination  $0.6DL + 0.6W$ . Also considered is the appropriate inward wind pressure, 20 psf live load and the weight of the panel.

\* - Indicates that Support Straps must be installed per the Approval.

① FIF D  
 ② EDGE  
 ③ CORNER  
 A  
 B  
 LEAST OF 10% SLOPE OR 1/4" IS USED FOR 12:12 OR STEEPER SLOPES. BUT NOT LESS THAN 8"