

Wall Fastener Spacing (feet)

Wind Speed (mph) Exposure Category
120C

	Field	Edge
Gauge	-22.7 psf	-28.1 psf
26 ga	4.00	4.00

130C

	Field	Edge
Gauge	-26.7 psf	-33 psf
26 ga	4.00	4.00

140C

	Field	Edge
Gauge	-31 psf	-38.2 psf
26 ga	4.00	4.00

150C

	Field	Edge
Gauge	-35.5 psf	-43.9 psf
26 ga	4.00	3.50

160C

	Field	Edge
Gauge	-40.4 psf	-49.9 psf
26 ga	3.75	3.00

170C

	Field	Edge
Gauge	-45.7 psf	-56.4 psf
26 ga	3.50	2.75

180C

	Field	Edge
Gauge	-51.2 psf	-63.2 psf
26 ga	3.00	2.50

190C

	Field	Edge
Gauge	-57 psf	-70.4 psf
26 ga	2.75	2.25

Notes:

1. Allowable spacing is based on a Design Pressures listed in the FBC 2017 Approval, FL9482.6 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.

2. Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 25 feet.

3. Allowable spacing is determined for wind pressure and suction using the combination 0.6W for each.

- ④ - FIELD
- ⑤ - EDGE

a - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

