



Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.47:12				Roof Slope: 1.47:12 to 6.11:12			Roof Slope: 6.11:12 to 12:12			
	Thickness	zone 1'	zone 1	zone 2	zone 3	zone 1,2e	z 2n,2r,3e	zone 3r	z 1,2e,2r	z 2n,3r	zone 3e
100D	26 ga	2.00	1.50	1.00	0.50	1.00	0.50	0.50	1.00	1.00	0.50
		-15.3 psf	-27.1 psf	-35.9 psf	-49.1 psf	-31.5 psf	-46.2 psf	-55 psf	-28.6 psf	-31.5 psf	-49.1 psf
110D	26 ga	2.00	1.00	0.50	0.50	1.00	0.50	0.50*	1.00	1.00	0.50
		-18.7 psf	-32.9 psf	-43.6 psf	-59.6 psf	-38.2 psf	-56 psf	-66.7 psf	-34.7 psf	-38.2 psf	-59.6 psf
120D	26 ga	1.50	1.00	0.50	0.50*	0.50	0.50*	0.50*	1.00	0.50	0.50*
		-22.3 psf	-39.2 psf	-51.9 psf	-71 psf	-45.6 psf	-66.8 psf	-79.5 psf	-41.4 psf	-45.6 psf	-71 psf
130D	26 ga	1.50	0.50	0.50	0.50*	N.G.	N.G.	N.G.	0.50	0.50	0.50*
		-26.3 psf	-46.2 psf	-61.1 psf	-83.4 psf	-53.6 psf	-78.5 psf	-93.4 psf	-48.6 psf	-53.6 psf	-83.4 psf
140D	26 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.
		-30.6 psf	-53.6 psf	-70.9 psf	-96.8 psf	-62.3 psf	-91.1 psf	-108.4 psf	-56.5 psf	-62.3 psf	-96.8 psf
150D	26 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.
		-35.2 psf	-61.6 psf	-81.5 psf	-111.2 psf	-71.6 psf	-104.6 psf	-124.5 psf	-64.9 psf	-71.6 psf	-111.2 psf
160D	26 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.
		-40.1 psf	-70.2 psf	-92.8 psf	-126.6 psf	-81.5 psf	-119.1 psf	-141.7 psf	-74 psf	-81.5 psf	-126.6 psf
170D	26 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.
		-45.3 psf	-79.3 psf	-104.8 psf	-143 psf	-92.1 psf	-134.5 psf	-160 psf	-83.6 psf	-92.1 psf	-143 psf

Notes:

1. Allowable spacing is based on a Design Pressures listed in the FBC 2020 Approval, FL14645.11 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.

2. Allowable spacing is based on an applied load determined using ASCE 7-16 for the Wind Speeds, Wind Exposure Categories, "Roof Slopes, and Roof Zones shown, assuming 10 square feet of tributary area, Enclosed Gable Roof, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 25 feet.

3. Allowable spacing is determined for wind suction using the pressures shown, resulting from the combination $0.6DL + 0.6W$. Also considered is the inward wind pressure, 20 psf live load and the weight of the panel.

* - Indicates that SM 7108 Adhesive is required in the panel rib.

#N/A

