



## Roof Fastener Spacing (feet)

Wind Speed (mph)  
Exposure Category  
**110C**

Roof Slope: 0.5:12 to 1.47:12				
Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50

Roof Slope: 1.48:12 to 6.11:12		
zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50	0.50

Roof Slope: 6.12:12 to 12:12		
z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50

**120C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50

zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50	0.50

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50

**130C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50

zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50	0.50

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50

**140C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50

zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50	0.50

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50

**150C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50

zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50	0.50*

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50

**160C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50*

zone 1,2e	z 2n,2r,3e	zone 3r
0.50	0.50*	0.50*

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50*

**170C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	0.50	0.50	0.50	0.50*

zone 1,2e	z 2n,2r,3e	zone 3r
N.G.	N.G.	N.G.

z 1,2e,2r	z 2n,3r	zone 3e
0.50	0.50	0.50*

**180C**

Thickness	zone 1'	zone 1	zone 2	zone 3
26 ga	N.G.	N.G.	N.G.	N.G.

zone 1,2e	z 2n,2r,3e	zone 3r
N.G.	N.G.	N.G.

z 1,2e,2r	z 2n,3r	zone 3e
N.G.	N.G.	N.G.

**Notes:**

- Allowable spacing is based on a Design Pressures listed in the Miami-Dade NOA, 23-0711.05 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-16 for the Wind Speeds, Wind Exposure Categories, "Roof Slopes, and Roof Zones shown, assuming 10 square feet of tributary area, Enclosed Gable Roof, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 30 feet.
- Allowable spacing is determined for wind suction using the pressures shown, resulting from the combination  $0.6DL + 0.6W$ . Also considered is the inward wind pressure, 20 psf live load and the weight of the panel.

\* - Indicates that SM 7108 Adhesive is required in the panel rib.

