

Roof Clip Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.47:12				Roof Slope: 1.48:12 to 6.11:12			Roof Slope: 6.12:12 to 12:12			
	zone 1'	zone 1	zone 2	zone 3	zone 1	zone 2	zone 3	zone 1	zone 2	zone 3	
100C	Thickness	-13.1 psf	-23.4 psf	-31.1 psf	-42.6 psf	-27.2 psf	-36.2 psf	-47.7 psf	-24.7 psf	-27.2 psf	-42.6 psf
	24 ga	4.00	4.00	3.67	2.67	4.00	3.00	2.33	4.00	4.00	2.67
110C	Thickness	-16 psf	-28.4 psf	-37.7 psf	-51.7 psf	-33.1 psf	-44 psf	-57.9 psf	-30 psf	-33.1 psf	-51.7 psf
	24 ga	4.00	4.00	3.00	2.00	3.33	2.67	2.00	4.00	3.33	2.00
120C	Thickness	-19.2 psf	-34 psf	-45.1 psf	-61.7 psf	-39.5 psf	-52.5 psf	-69.1 psf	-35.8 psf	-39.5 psf	-61.7 psf
	24 ga	4.00	3.33	2.33	1.67	3.00	2.00	1.67	3.33	3.00	1.67
130C	Thickness	-22.7 psf	-40 psf	-53 psf	-72.5 psf	-46.5 psf	-61.7 psf	-81.2 psf	-42.2 psf	-46.5 psf	-72.5 psf
	24 ga	4.00	2.67	2.00	1.33	2.33	1.67	1.00	2.67	2.33	1.33
140C	Thickness	-26.4 psf	-46.5 psf	-61.6 psf	-84.2 psf	-54.1 psf	-71.7 psf	-94.3 psf	-49 psf	-54.1 psf	-84.2 psf
	24 ga	4.00	2.33	1.67	1.00*	2.00	1.33	1.00*	2.33	2.00	1.00*
150C	Thickness	-30.4 psf	-53.5 psf	-70.8 psf	-96.8 psf	-62.2 psf	-82.4 psf	-108.3 psf	-56.4 psf	-62.2 psf	-96.8 psf
	24 ga	3.67	2.00	1.67	1.00*	N.G.	N.G.	N.G.	2.00	1.67	1.00*
160C	Thickness	-34.7 psf	-61 psf	-80.7 psf	-110.2 psf	-70.8 psf	-93.8 psf	-123.4 psf	-64.3 psf	-70.8 psf	-110.2 psf
	24 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.
170C	Thickness	-39.3 psf	-68.9 psf	-91.2 psf	-124.5 psf	-80.1 psf	-106 psf	-139.4 psf	-72.6 psf	-80.1 psf	-124.5 psf
	24 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.

Notes:

1. Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL11560.8 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.

2. Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, "Roof Slopes, and Roof Zones shown, assuming 10 square feet tributary area, Enclosed Gable Roof, 3 or more equal span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado Loads are not considered.

3. Allowable spacing is determined for wind suction using the pressures shown, resulting from the combination $0.6DL + 0.6W$. Also considered is the inward wind pressure, 20 psf live load and the weight of the panel.

* - Indicates that Geocel 4600 Adhesive is required in the panel rib.

