

## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

Thickness	Field	Edge
24 ga	-19.4 psf 6.00	-24 psf 5.50

110D
------

Thickness	Field	Edge
24 ga	-23.5 psf 5.50	-29 psf 4.50

120D
------

Thickness	Field	Edge
24 ga	-28 psf 4.50	-34.5 psf 3.50

130D
------

Thickness	Field	Edge
24 ga	-32.8 psf 4.00	-40.5 psf 3.00

140D
------

Thickness	Field	Edge
24 ga	-38.1 psf 3.50	-47 psf 2.50

150D
------

Thickness	Field	Edge
24 ga	-43.7 psf 3.00	-53.9 psf 2.50

160D
------

Thickness	Field	Edge
24 ga	-49.7 psf 2.50	-61.4 psf 2.00

170D
------

Thickness	Field	Edge
24 ga	-56.1 psf N.G.	-69.3 psf N.G.


### Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
- Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

N.G. indicates the panel is not recommended for this application.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

Thickness	Field	Edge
24 ga	6.00	6.00

110D
------

Thickness	Field	Edge
24 ga	6.00	5.00

120D
------

Thickness	Field	Edge
24 ga	5.00	4.00

130D
------

Thickness	Field	Edge
24 ga	4.50	3.50

140D
------

Thickness	Field	Edge
24 ga	3.50	3.00

150D
------

Thickness	Field	Edge
24 ga	3.00	2.50

160D
------

Thickness	Field	Edge
24 ga	2.50	2.00

170D
------


Thickness	Field	Edge
24 ga	2.50	2.00

### Notes:

1. Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
2. Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
3. Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

	Field	Edge
Thickness	-19.4 psf	-24 psf
24 ga	5.00	4.00

110D
------

	Field	Edge
Thickness	-23.5 psf	-29 psf
24 ga	4.00	3.50

120D
------

	Field	Edge
Thickness	-28 psf	-34.5 psf
24 ga	3.50	2.50

130D
------

	Field	Edge
Thickness	-32.8 psf	-40.5 psf
24 ga	3.00	2.50

140D
------

	Field	Edge
Thickness	-38.1 psf	-47 psf
24 ga	2.50	2.00

150D
------

	Field	Edge
Thickness	-43.7 psf	-53.9 psf
24 ga	N.G.	N.G.

160D
------

	Field	Edge
Thickness	-49.7 psf	-61.4 psf
24 ga	N.G.	N.G.

170D
------

	Field	Edge
Thickness	-56.1 psf	-69.3 psf
24 ga	N.G.	N.G.


### Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
- Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

N.G. indicates the panel is not recommended for this application.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

Thickness	Field	Edge
24 ga	6.00	5.00

110D
------

Thickness	Field	Edge
24 ga	5.00	4.00

120D
------

Thickness	Field	Edge
24 ga	4.50	3.50

130D
------

Thickness	Field	Edge
24 ga	3.50	3.00

140D
------

Thickness	Field	Edge
24 ga	3.00	2.50

150D
------


Thickness	Field	Edge
24 ga	2.50	2.00

160D
------

Thickness	Field	Edge
24 ga	2.50	2.00

170D
------

Thickness	Field	Edge
24 ga	2.00	2.00

<p><b>Notes:</b></p> <ol style="list-style-type: none"> <li>Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.</li> <li>Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.</li> <li>Allowable spacing is determined for wind pressure and suction using the combination <math>0.6W</math> for each.</li> </ol>	<p><b>a</b> - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.</p> <p>④ - FIELD ⑤ - EDGE</p> 
--	---

## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

	Field	Edge
Thickness	-19.4 psf	-24 psf
24 ga	5.00	4.00

110D
------

	Field	Edge
Thickness	-23.5 psf	-29 psf
24 ga	4.00	3.50

120D
------

	Field	Edge
Thickness	-28 psf	-34.5 psf
24 ga	3.50	2.50

130D
------

	Field	Edge
Thickness	-32.8 psf	-40.5 psf
24 ga	3.00	2.50

140D
------

	Field	Edge
Thickness	-38.1 psf	-47 psf
24 ga	2.50	2.00

150D
------

	Field	Edge
Thickness	-43.7 psf	-53.9 psf
24 ga	N.G.	N.G.

160D
------

	Field	Edge
Thickness	-49.7 psf	-61.4 psf
24 ga	N.G.	N.G.

170D
------

	Field	Edge
Thickness	-56.1 psf	-69.3 psf
24 ga	N.G.	N.G.


### Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
- Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

N.G. indicates the panel is not recommended for this application.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

Thickness	Field	Edge
24 ga	-19.4 psf 6.00	-24 psf 5.00

110D
------

Thickness	Field	Edge
24 ga	-23.5 psf 5.00	-29 psf 4.00

120D
------

Thickness	Field	Edge
24 ga	-28 psf 4.50	-34.5 psf 3.50

130D
------

Thickness	Field	Edge
24 ga	-32.8 psf 3.50	-40.5 psf 3.00

140D
------

Thickness	Field	Edge
24 ga	-38.1 psf 3.00	-47 psf 2.50

150D
------

Thickness	Field	Edge
24 ga	-43.7 psf 2.50	-53.9 psf 2.00

160D
------

Thickness	Field	Edge
24 ga	-49.7 psf 2.50	-61.4 psf 2.00

170D
------


Thickness	Field	Edge
24 ga	-56.1 psf 2.00	-69.3 psf 2.00

### Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
- Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

**a** - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

	Field	Edge
Thickness	-19.4 psf	-24 psf
24 ga	5.00	4.00

110D
------

	Field	Edge
Thickness	-23.5 psf	-29 psf
24 ga	4.00	3.50

120D
------

	Field	Edge
Thickness	-28 psf	-34.5 psf
24 ga	3.50	2.50

130D
------

	Field	Edge
Thickness	-32.8 psf	-40.5 psf
24 ga	3.00	2.50

140D
------

	Field	Edge
Thickness	-38.1 psf	-47 psf
24 ga	2.50	2.00

150D
------

	Field	Edge
Thickness	-43.7 psf	-53.9 psf
24 ga	N.G.	N.G.

160D
------

	Field	Edge
Thickness	-49.7 psf	-61.4 psf
24 ga	N.G.	N.G.

170D
------

	Field	Edge
Thickness	-56.1 psf	-69.3 psf
24 ga	N.G.	N.G.


### Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
- Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

N.G. indicates the panel is not recommended for this application.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE



## Wall Clip Spacing (feet)

Wind Speed (mph) Exposure Category
100D

	Field	Edge
Thickness	-19.4 psf	-24 psf
24 ga	6.00	5.00

110D
------

	Field	Edge
Thickness	-23.5 psf	-29 psf
24 ga	5.00	4.00

120D
------

	Field	Edge
Thickness	-28 psf	-34.5 psf
24 ga	4.50	3.50

130D
------

	Field	Edge
Thickness	-32.8 psf	-40.5 psf
24 ga	3.50	3.00

140D
------

	Field	Edge
Thickness	-38.1 psf	-47 psf
24 ga	3.00	2.50

150D
------

	Field	Edge
Thickness	-43.7 psf	-53.9 psf
24 ga	2.50	2.00

160D
------

	Field	Edge
Thickness	-49.7 psf	-61.4 psf
24 ga	2.50	2.00

170D
------

	Field	Edge
Thickness	-56.1 psf	-69.3 psf
24 ga	2.00	2.00

### Notes:

1. Allowable spacing is based on a Design Pressures listed in the FBC 2023 Approval, FL34027.3 and determined by interpolation of those values. 1/3 increase is not included for wind. The fasteners and fastening patterns are shown in the Approval.
2. Allowable spacing is based on an applied load determined using ASCE 7-22 for the Wind Speeds, Wind Exposure Categories, assuming 10 square feet " of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1 and Mean Roof Height of 30 feet. Tornado loads are not considered.
3. Allowable spacing is determined for wind pressure and suction using the combination  $0.6W$  for each.

$a$  - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF MEAN ROOF HEIGHT BUT NOT LESS THAN 3'.

- ④ - FIELD
- ⑤ - EDGE

